

# Premier PAT Testing



Call Free On  
**0800 046 9279**



[www.premier-pat-testing.com](http://www.premier-pat-testing.com)  
[team@premier-pat-testing.com](mailto:team@premier-pat-testing.com)

## Details of Client

## Certificate Number

**Wayne Davies (BPM Discos)**

**153**

## Test Equipment Details

Test Equipment Used: Kewtech KT71

Serial Number:

7005071

Tested By: Ben McCarthy

Test Date: 16/06/2009

Retest Date:

16/06/2010

Serial Number	Description	Location	Class	Insulation Resistance	Earth Continuity	Plug, flex and body	OK to Use?
1	4 Way Extension	Mobile		>20 Ω /M	0.05	OK	Yes
2	Martin Wizard Extreme	Mobile		>20 Ω /M	0.19	OK	Yes
3	Laptop Power Adaptor	Mobile		>20 Ω /M	*	OK	Yes
4	LED Par Can	Mobile		>20 Ω /M	0.01	OK	Yes
5	LED Par Can	Mobile		>20 Ω /M	0.02	OK	Yes
6	Smoke Machine	Mobile		>20 Ω /M	0.06	OK	Yes
7	30m Ext Cable	Mobile		>20 Ω /M	0.43	OK	Yes
8	Radio Mic Receiver	Mobile		>20 Ω /M	*	OK	Yes
9	Mackie SRM 450	Mobile		>20 Ω /M	0.05	OK	Yes
10	Mackie SRM 450	Mobile		>20 Ω /M	0.08	OK	Yes
11	IEC Lead	Mobile		>20 Ω /M	0.01	OK	Yes
12	IEC Lead	Mobile		>20 Ω /M	0.02	OK	Yes

